



a **Bodycote** (Materials Testing Engineering and Technology) Company
www.bodycote.com
www.warringtonfire.net

Report Sponsor

Issue Date

Am-boss Access Ladders Pty Ltd
11-13 Maida Ave,
Sunshine North, VIC 3020

28/01/09

Introduction

The element of construction described below was assessed by this laboratory on behalf of the report sponsor in accordance with the stated test standard and achieved the results stated below. Refer to the referenced assessment and test report(s) for more information.

Referenced Report

Validity Date

Referenced Test Standard

BWA 22794-01

31/01/2014

AS1530.4-2005

Description of Product

Product name

Size

Product Description

Am-boss, 'Access Boss' pull down access ladder

Ceiling mounted access hatch and ladder assembly with steel lock.

Description of Assessed Construction

The assessed construction comprised an Am-boss, 'Access Boss' pull down Access ladder assembly mounted in a suspended steel grid ceiling system with 3-off Layers of 16 mm thick Fyrchek plasterboard and requires a minimum plenum (or ceiling cavity space) above to be 500mm.

Summary of Fire Resistance

Am-boss Hatch FRL

-/90/90

Resistance to Incipient Spread (RISF)

90 minutes

TESTING AUTHORITY

Address

Bodycote Warringtonfire (Aus) Pty Ltd 2009
PO Box 4282 DANDENONG SOUTH VIC 3184
Unit 2, 409-411 Hammond Road DANDENONG VIC 3175

Phone / Fax

61 (0)3 9767 1066 / 61 (0)3 9767 1001

ABN

81 050 241 524

Email / Home Page

testing@wfr.com.au / www.wfr.com.au

Authorisation

Prepared By:

Reviewed By:

Ashley Bicknell

A. D. Bicknell

K. G. Nicholls