

FIRE TEST RESULTS

everroll® Rubber Flooring Collection

NCC 2014 SPECIFICATION CLASS C1.10 FIRE HAZARD PROPERTIES – CLAUSE 4 WALL LININGS AND CEILING LININGS

Table 3 – WALL AND CEILING LINING MATERIALS

Class of Building	Fire-isolated Exists and Fire Control Rooms Wall/ceiling	Public corridors		Specific Areas		Other areas Wall/ceiling
		Wall	Ceiling	Wall	Ceiling	
Class 2 or 3, Excluding accommodation for the aged, people with disabilities, and children						
Unsprinklered	1	1,2	1,2	1,2,3	1,2,3	1,2,3
Sprinklered	1	1,2,3	1,2,3	1,2,3	1,2,3	1,2,3
Class 3 or 9a, Accommodation for the aged, people with disabilities, children and health-care buildings						
Unsprinklered	1	1	1	1,2	1,2	1,2,3
Sprinklered	1	1,2	1,2	1,2,3	1,2,3	1,2,3
Class 5,6,7,8 or 9b schools						
Unsprinklered	1	1,2	1,2	1,2,3	1,2	1,2,3
Sprinklered	1	1,2,3	1,2,3	1,2,3	1,2,3	1,2,3
Class 9b other than schools						
Unsprinklered	1	1	1	1,2	1,2	1,2,3
Sprinklered	1	1,2	1,2	1,2,3	1,2,3	1,2,3
Class 9c						
Sprinklered	1	1,2	1,2	1,2,3	1,2,3	1,2,3

For the purpose of this Table

1. "Sprinklered" means a building fitted with a sprinkler system complying with Specification E1.5.
2. "Specific Areas" means within:
 - a. For Class 2 and 3 building, a sole-occupancy unit.
 - b. For Class 5 buildings, open plan offices with a minimum floor dimension/floor to ceiling height ratio >5.
 - c. For Class 6 building, shops or other building with a minimum floor dimension/floor to ceiling height ratio >5.
 - d. For Class 9a health-care building, patient care areas.
 - e. For Class 9b theatres and halls etc. an auditorium.
 - f. For Class 9b schools, a classroom
 - g. For Class 9c aged care building, resident use areas.
3. Buildings not fitted with a sprinkler must have an average extinction area less than 250m²/Kg

Table 2 - REGUPOL RESULTS

Regupol Product	Group Number	Average Specific Extinction Area	Test in accordance to	Test Report
everroll® Active	3	105.1m ² /Kg	AS/NZ 3837	CSIRO No. 2136
everroll® Shape	3	105.1m ² /Kg	AS/NZ 3837	CSIRO No. 2136